

# Supplier Declaration of Compliance

(In accordance with Regulation 101A of the Electricity Regulations 1997)

Ministry of Economic Development



Manatū Ōhanga

Energy Safety

THIS COMPLETED FORM REMAINS WITH THE SUPPLIER AS PART OF THE DOCUMENTATION REQUIRED FOR THE 'COMPLIANCE FOLDER'  
DO NOT SUBMIT THIS FORM TO THE MINISTRY

## Suppliers Details

Name (of New Zealand manufacturer, importer or agent)

Weiss (NZ) Ltd

Address

20b Arwen Place

New Zealand Company Number (if applicable)

1204760

East Tamaki

Auckland

## Product Details

Product name, type, model and serial numbers (if applicable)

FH800

Documents used as the basis for compliance with regulation 69

Spectrum Laboratories Test Report Number 2867B

EMC Compliance

This is a Level One product with a C frame motor that has a very low risk of causing EMC interference

## Declaration

I hereby declare that the above specified fittings or electrical appliances comply with the requirements of

Signature of Authorised Person

Print Name

M Desmond

Position in Organisation

Technical

Date 05-Apr-2011



FH600 AIR TEMPERING UNIT  
230-240 VOLT 50Hz AC 1100 WATT

When installed this unit must be installed horizontal and this label must be at the top of this unit



Over Temperature reset switch

Minimum Air Delivery 63 litres/sec

Approval Number.

2867

Batch: 0880007

Please follow all installation instructions carefully.

AIRFLOW DIRECTION

